

**TOWNSHIP OF WARREN  
RESOLUTION NO. 2022-108**

**AUTHORIZING INSTALLATION OF EIGHT (8) FIRE HYDRANTS  
HILLCREST CROSSING / HILLCREST ROAD AND ROUTE 78**

**BE IT RESOLVED** by the Township Committee of the Township of Warren, in the County of Somerset, New Jersey, that the Warren Township Fire Marshal approved the locations of eight (8) new fire hydrants at the Hillcrest Crossing project, located at Hillcrest Route and Route 78, as shown on the attached map with two (3) hydrants located in the Public Right-of-Way and five (5) hydrants located on Private Property.

**BE IT FURTHER RESOLVED** that financial responsibility and fees to New Jersey American Water Company for the five (5) hydrants located on Private Property are the responsibility of the Property Owner and that financial responsibility and fees to New Jersey American Water Company for the three (3) hydrants located in the Public Right-of-Way are the responsibility of the Township of Warren.

**BE IT FURTHER RESOLVED** New Jersey American Water Company should provide certification indicating adequate residual minimum pressure of 20 psi be maintained as well as an acceptable flow test to be run prior to placing these systems in operation.

INTRODUCED	SECONDED	COMMITTEE	AYE	NAY	ABSTAIN	ABSENT
		MAZIARZ	X			
		MARION	X			
X		LAZO	X			
	X	DINARDO	X			
		SORDILLO	X			

CERTIFICATION

I, Cathy Reese, Township Clerk of the Township of Warren, in the County of Somerset, New Jersey, do hereby certify the foregoing to be a true and correct copy of a resolution adopted at a meeting of the Township Committee held on April 14, 2022.

Cathy Reese, RMC  
Township Clerk